



QUALITY CONTROL SUB DISTRICT LAB

KERALA WATER AUTHORITY
AMBALAPPUZHA, VAZHICHERY, ALAPPUZHA

Telephone No. 0477-2966650

Email : qcqsdlabpuzha@gmail.com

Report No: 854/A/2026		Date: 17/04/2026	
Customer Name & Address Holy Family V P S Kattoor	1.Date of Receipt	: 10/04/2026	
	2.Sampling done by	: HI, RHTC Chettikad	
	3.Sample Code	: 2026/QCSDL/AMB/A 854	
	4.Source of Sample	: R O Water	
	5.Sample Quantity	: 250 ml	
	6.Test performing dates	From: 13/04/2026	To: 17/04/2026

BACTERIOLOGICAL ANALYSIS


Sl. No	Parameters	Acceptable limits as per – IS 10500 – 2012	Test Method	Result
1	Coliforms	Shall not be detected/100 ml	IS15185:2016	ABSENT
2	E-coli	Shall not be detected/100 ml	IS15185:2016	ABSENT

Remarks:-

NB:-The results stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Test Method:
Coliform - Membrane Filtration Method
E- Coli- Membrane Filtration Method




Authorized by

Page 1-1

End of the report

SANITARY CERTIFICATE

PH NO: 12/2026

Dated:21/04/2026

REF:No:696/2026 RHTC

RHTC Chettikadu

GRN-NO-KL052722099202526E

This is to Certify that I have Inspected the Sanitary condition of the HOLY FAMILY VISITATION PUBLIC SCHOOL ,KATTOOR , visited on 10/04/2026 3.00 PM bearing Building No 19/7 55B of SUPERIOR,VISITATION , CONVENTSQUARE ALAPPUZHA .

The Sanitary Condition of the Premises of the Building is found Satisfactory. This Certificate is valid for one year from the date of issue.



[Signature]
HEALTH INSPECTOR

HEALTH INSPECTOR
RURAL HEALTH TRAINING CENTRE
CHETTİKAD